Phone Office/Lab (02) 6775 1157

ABN: 72 212 385 096

email: lanfaxlabs@bigpond.com.au
Website: temporarily off-line
Lab address: 493 Old Inverell Road
Postal: PO Box 4690 Armidale NSW 2350

Director: Dr Robert Patterson CPSS,

Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works Report 2ND February 2025 Water Sample collected 28th January 2025 Analysis complete 2nd February 2025 Sample collected by Emily Leach Samples received chilled 28th January 2025

RESULTS - GLEN INNES - 28th January 2025

mg L⁻¹ = part per million)

Parameter		EPA Limit 90 th %ile	Units	Method		
Ammonia NH ₃ -N	0.63	2.0	mg L ⁻¹	APHA 4500-NH ₃ C		
Biochemical Oxygen Demand (5 days)	2.6	10	mg L ⁻¹	APHA 5210 B		
Elect. conductivity (EC)	752		uS cm ⁻¹	APHA 2510 B		
Faecal Coliforms	92	200	cfu/ 100 mL	Membrane Filter APHA 9222 D		
NO ₂ and NO ₃ -N	3.38		mg L ⁻¹	APHA 4110 B		
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664		
pН	7.17	6.8-8.5	pH units	APHA 4500-H ⁺ B		
Soluble Reactive P (SRP)	0.03		mg L ⁻¹	APHA 4110 B		
Total phosphorus	0.12	0.3	mg L ⁻¹	APHA 4500 P E		
TKN - N	0.9		mg L ⁻¹	APHA 4500-N _{org} C		
TN	4.3	10	mg L ⁻¹	$TKN + NO_2 + NO_3$		
Total suspended solids TSS	8	15	mg L ⁻¹	APHA 2540 D		

0 < 0.x = measured but reading below detection level

Reference: APHA (2005) Standard Meth230ods for the Examination of Water and Wastewater. 21st Edition 2005. **Comments**. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes STP - elemental analysis										
7	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen Innes-28JAN2	mg/L	mg/L	mg/L	mg/L	D 2000	mg/L	mg/L	mg/L	mg/L	mg/L
	75.1	19.7	24.8	33.5	2.4	186	81.1	504	55	60

