Phone Office/Lab (02) 6775 1157 ABN: 72 212 385 096

email: <u>lanfaxlabs@bigpond.com.au</u> Website: <u>http://www.lanfaxlabs.com.au</u> Lab address: 493 Old Inverell Road Postal: PO Box 4690 Armidale NSW 2350 Director: Dr Robert Patterson CPSS, Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works Report 6th October 2024 Water Sample collected 1st October 2024 Analysis complete 6th October 2024 Sample collected by Emily Leach Samples received chilled 1st October 2024

Parameter		EPA Limit 90 th %ile	Units	Method
Ammonia NH ₃ -N	0.99	2.0	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	7.3	10 mg L ⁻¹ APHA 5210		APHA 5210 B
Elect. conductivity (EC)	689		uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	5	200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	1.72		mg L ⁻¹	APHA 4110 B
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664
рН	7.28	6.8-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.07		mg L ⁻¹	APHA 4110 B
Total phosphorus	0.14	0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	2.5		mg L ⁻¹	APHA 4500-N _{org} C
TN	4.2	10	mg L ⁻¹	$TKN + NO_2 + NO_3$
Total suspended solids TSS	5	15	mg L ⁻¹	APHA 2540 D

RESULTS - GLEN INNES - 1st October 2024

0 < 0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Meth230ods for the Examination of Water and Wastewater*. 21st Edition 2005. **Comments**. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis													
OCTOBER 2024	Na	к	Mg	Са	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride			
Glen Innes -	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L			
010CT24	70.5	15.7	25.7	31.7	2.3	185	54.5	462	92	54			



Commercial and research laboratory for soil, water and plant analysis. Soil survey and analytical assessments, landscape analysis and plant nutrient relationships, Wastewater and effluent reuse specialists - on-site and decentralised