Phone Office/Lab (02) 6775 1157

ABN: 72 212 385 096

email: <u>lanfaxlabs@bigpond.com.au</u>
Website: <u>http://www.lanfaxlabs.com.au</u>

Lab address: 493 Old Inverell Road Postal: PO Box 4690 Armidale NSW 2350

Director: Dr Robert Patterson CPSS,

Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

Analysis of Water Sample

Client Glen Innes Severn Council.

Glen Innes Sewage Treatment Works Report 12th November 2024 Water Sample collected 5th November 2024 Analysis complete 12th November 2024

Sample collected by Emily Leach

Samples received chilled 29th October 2024

RESULTS - GLEN INNES - 5th November 2024

mg L⁻¹ = part per million)

Parameter		EPA Limit 90 th %ile	Units	Method	
Ammonia NH ₃ -N	0.88	2.0	mg L ⁻¹	APHA 4500-NH ₃ C	
Biochemical Oxygen Demand (5 days)	7.1	10	mg L ⁻¹	APHA 5210 B	
Elect. conductivity (EC)	835		uS cm ⁻¹	APHA 2510 B	
Faecal Coliforms	32	200	cfu/ 100 mL	Membrane Filter APHA 9222 D	
NO ₂ and NO ₃ -N	3.98		mg L ⁻¹	APHA 4110 B	
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664	
pН	7.20	6.8-8.5	pH units	APHA 4500-H ⁺ B	
Soluble Reactive P (SRP)	0.14		mg L ⁻¹	APHA 4110 B	
Total phosphorus	0.15	0.3	mg L ⁻¹	APHA 4500 P E	
TKN - N	3.5		mg L ⁻¹	APHA 4500-N _{org} C	
TN	7.5	10	mg L ⁻¹	$TKN + NO_2 + NO_3$	
Total suspended solids TSS	3	15	mg L ⁻¹	APHA 2540 D	

0 < 0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Meth230ods for the Examination of Water and Wastewater*. 21st Edition 2005. **Comments**. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes Weir - elemental analysis											
November 2024	Na	V	Ma	Ca	CAD	Hardness	Sulphur	TDS	Alkalinity	Chloride	
	IVa	N.	Mg	Ca	SAR	Hardness	Sulpriur	103	Alkalinity	Chionae	
Glen Innes -	mg/L	mg/L	mg/L	mg/L	26.91	mg/L	mg/L	mg/L	mg/L	mg/L	
05NOV24	87.9	21.4	28.7	36.2	2.6	209	72.4	559	93	71	

