

Phone Office/Lab (02) 6775 1157  
 ABN: 72 212 385 096  
 email: [lanfaxlabs@bigpond.com.au](mailto:lanfaxlabs@bigpond.com.au)  
 Website: <http://www.lanfaxlabs.com.au>  
 Lab address: 493 Old Inverell Road  
 Postal: PO Box 4690 Armidale NSW 2350  
 Director: Dr Robert Patterson CPSS,  
 Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

## Analysis of Water Sample

Client Glen Innes Severn Council,  
 Glen Innes Sewage Treatment Works Report 18<sup>th</sup> November 2024  
 Water Sample collected 12<sup>th</sup> November 2024 Analysis complete 18<sup>th</sup> November 2024  
 Sample collected by Emily Leach Samples received chilled 29<sup>th</sup> October 2024

## RESULTS - GLEN INNES - 12<sup>th</sup> November 2024

mg L<sup>-1</sup> = part per million)

Parameter			EPA Limit 90 <sup>th</sup> %ile	Units	Method
Ammonia NH <sub>3</sub> -N	0.94		2.0	mg L <sup>-1</sup>	APHA 4500-NH <sub>3</sub> C
Biochemical Oxygen Demand (5 days)	9.8		10	mg L <sup>-1</sup>	APHA 5210 B
Elect. conductivity (EC)	798			uS cm <sup>-1</sup>	APHA 2510 B
Faecal Coliforms	42		200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO <sub>2</sub> and NO <sub>3</sub> -N	3.02			mg L <sup>-1</sup>	APHA 4110 B
Oil & Grease	<2		2	mg L <sup>-1</sup>	USEPA 1664
pH	7.2		6.8-8.5	pH units	APHA 4500-H <sup>+</sup> B
Soluble Reactive P (SRP)	0.03			mg L <sup>-1</sup>	APHA 4110 B
Total phosphorus	0.17		0.3	mg L <sup>-1</sup>	APHA 4500 P E
TKN - N	4.3			mg L <sup>-1</sup>	APHA 4500-N <sub>org</sub> C
TN	7.3		10	mg L <sup>-1</sup>	TKN + NO <sub>2</sub> +NO <sub>3</sub>
Total suspended solids TSS	13		15	mg L <sup>-1</sup>	APHA 2540 D

0<0.x = measured but reading below detection level

Reference: APHA (2005) *Standard Methods for the Examination of Water and Wastewater*. 21st Edition 2005.

Comments. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes STP - elemental analysis										
November 2024	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
Glen	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
Innes-12NOV24	83.9	19.0	26.1	32.9	2.6	190	68.0	535	78	79



Commercial and research laboratory for soil, water and plant analysis.  
 Soil survey and analytical assessments, landscape analysis and plant nutrient relationships,  
 Wastewater and effluent reuse specialists - on-site and decentralised