Phone Office/Lab (02) 6775 1157

ABN: 72 212 385 096

email: <u>lanfaxlabs@bigpond.com.au</u>
Website: <u>http://www.lanfaxlabs.com.au</u>

Lab address: 493 Old Inverell Road Postal: PO Box 4690 Armidale NSW 2350

Director: Dr Robert Patterson CPSS,

Soil Scientists and Environmental Engineers



Quality Assurance and Quality Control by Approved Methods

Analysis of Water Sample

Client Glen Innes Severn Council,

Glen Innes Sewage Treatment Works

Report 21st July 2024

Water Sample collected 16th July 2024 Analysis complete 21st July 2024

Sample collected by Emily Leach

Samples received chilled 16th July 2024

RESULTS - GLEN INNES - 16th July 2024

mg L⁻¹ = part per million)

Parameter		EPA Limit 90 th %ile	Units	Method
Ammonia NH ₃ -N	1.02	2.0	mg L ⁻¹	APHA 4500-NH ₃ C
Biochemical Oxygen Demand (5 days)	7.1	10	mg L ⁻¹	APHA 5210 B
Elect. conductivity (EC)	700		uS cm ⁻¹	APHA 2510 B
Faecal Coliforms	<1	200	cfu/ 100 mL	Membrane Filter APHA 9222 D
NO ₂ and NO ₃ -N	2.14		mg L ⁻¹	APHA 4110 B
Oil & Grease	<2	2	mg L ⁻¹	USEPA 1664
рН	7.32	6.8-8.5	pH units	APHA 4500-H ⁺ B
Soluble Reactive P (SRP)	0.034		mg L ⁻¹	APHA 4110 B
Total phosphorus	0.18	0.3	mg L ⁻¹	APHA 4500 P E
TKN - N	4.0		mg L ⁻¹	APHA 4500-N _{org} C
TN	6.1	10	mg L ⁻¹	$TKN + NO_2 + NO_3$
Total suspended solids TSS	5	15	mg L ⁻¹	APHA 2540 D

0 < 0.x = measured but reading below detection level

Reference: APHA (2005) Standard Meth230ods for the Examination of Water and Wastewater. 21st Edition 2005. **Comments**. Please note the Lower detection limit under USEPA 1664 is 2 mg/L for Oil & Grease

Glen Innes STP - elemental analysis										
GlenInnes-16JUL2	Na	K	Mg	Ca	SAR	Hardness	Sulphur	TDS	Alkalinity	Chloride
	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	mg/L
	64.7	12.9	25.2	29.6	2.1	178	57.3	469	82	51

